


Gas-Fired Tempered Make-Up Air Unit

Model:

T2-3400-208-1

1-Phase, 208V, 2.00 HP, Belt driven with Motorized Damper and 12" Blower. MAX 3,400 CFM



Tel: (440) 365-4567

Fax: (440) 365-2100

www.naksinc.com







T2-HOX Direct Fired (481 lbs.)

Supply Motor:

Model L1322T, 2.00 HP, 208-1-60, 10.3 FLA, ODP (Open Drip Proof)

Supply Motor Pulleys:

Part Type	<u>Qt</u> y	Browning #	Turns Out
Blower Pulley	1	AK54 x 3/4	
Motor Pulley	1	1VP40 x 7/8	2.0

Burner:

Min Output BTU: 18,000 BTU/Hr Max Output BTU: 375,000 BTU/Hr

Size: 6" long Gas Type: Natural

Supply Performance:

Volume: 3400 cfm Volume Range: 1400-3400 cfm

RPM: 1072 TS: 3613 ft/min SP: 1.69" w.g.

0.50" Ext. + 0.80" Int. + 0.39" Opt.

BHP: 1.74

Heating Schedule:

Altitude: 0'

Winter Entering Air Dry Bulb Temp: 0°F

Temp Rise: 100°F Output BTU: 345,000 Input BTU: 375,000

BTUs BASED OFF STANDARD AIR DENSITY

Supply Installation Information:

Gas Inlet Pressure: 8 in. w.c. - 14 in. w.c.

Insurance: FM/ETL

Unit Main Input: 15.88 Amps MCA, 25 Amps MOP, 208 V,

12 AWG Wire Min.

Supply Unit Voltage: 208v-1ph-60hz

Construction Features

Housing constructed of heavy-duty unpainted G90 galvanized steel • Forward curved centrifugal blower wheel • Vibration isolation • Adjustable drive assemblies • Adjustable motor mount • Ball bearing motors • Heavy duty, pre-lubricated bearings L10 rated for 100,000 hours of operation • Static resistant belts • Service doors on both sides • Horizontal & down discharge • Large intake area ensures low pressure drop across unit • Electronic Burner Profiler System automatically adjusts for any airflow - no manual setting required! • Weatherproof safety disconnect switch • Modular design provides design flexibility • Fully insulated casing

Blower:

12" forward curved, centrifugal blower. Permanently lubricated ball bearings. Galvanized finish. 3/4" shaft. 2,500 max. RPM. Used in heated and non-heated supply fans.

Temp Control:

Maxitrol Series 14 • 40-90°F Discharge Temp Control • Field Wired On/Off Start Command; Temperature set point dial @ main/unit panel.

Intake:


Sloped Filtered Intake for T2 Modular Heater. 28" Wide x 32" Long x 30" High. Includes 2" MV EZ Kleen Metal Mesh Filters.


Filters:

2x MV EZ Kleen Metal Mesh Filter. 25"x 20"x 2" Used for heater and supply fan intakes.

Selected Options:

- Motorized Inlet Damper 20"W x 23-3/4"H for T2 Modular Heating Units w/Extended Shaft, Standard Galvanized Construction, 3/4" Rear Flange, LMX24-3-S Belimo Actuator Included (with end switch)
- Low Fire Start. Allows the burner circuit to energize when the modulation control is in a low fire position.





481 LBS.

TOTAL APPROXIMATE WEIGHT:

SA


3 5/16 🗖

		0	NO.
	MODEL:	DATE	DRAWING NO:
	-	ВМА	
PROJECT NAME:	REF NO/JOB NO.	DRAWN BY:	CERTIFIED BY:
DESCRIPTION OF REVISION	ı	ı	ı
ВУ	_	_	ı
DATE	1	1	ı
REV.	-	ı	1



CRIPTION OF REVISION – PROJECT NAME: –	- MODEL: T2-H0X TAG:	- BMA DATE: 08-2020 SCALE:	- CEPTIEIED RV. 172-3400-208-1
DESCRIPTION OF REVISION	ı	ı	ı
BY	-	1	1
DATE	_	-	ı
ZEV.	_	-	ı

NONE ı



Contractor:

Model Informa	tion											
Model	: G12				Part Nu	ımber:	900546	64				
CFM	3400		Shaft Diameter:			0.75		Unit	Weight:	48		
SP: 1.69			Wh	eel Dia	meter:	12.875 Ship Weight:			52			
RPM: 1072					Tip S	Speed:	3613 F	PM				
BHP	: 1.74			Sta	tic Effic	iency:	52		Е	levation:	0	
				0	utlet Ve	elocity:	2332 F	PM	Temp	perature:	70	
Sound Data	63	125	250	500	1000	2000	4000	8000	(Hz)	LwA:	85	

Sound Power Level @ Frequency, re: 10^12 Watts 89 91 86 82 77 77 74 71 (dB) SONES: 24.8


Ducted inlet or ducted outlet dBA @5 ft. 74


Ducted inlet and ducted outlet dBA @5 ft. 54

Performance Curve

Equipment Tag

DELHI Model G12 CFM=3400 SP=1.69 BHP=1.74 S. Eff=52% RPM=1072










115-1-60


208/230-1-60

208/230/460/575-3-60











PROJECT NAME:	NAKS T1-T5 DIRECT	FIRED M	IUA INSTALLAT	TON WIRING	
REF. NO./JOB NO.:	_	MODEL:	T1-T5	TAG:	_
DRAWN BY:	_	DATE:	06-2020	SCALE:	NONE
CERTIFIED BY:		DRAWING NO.: T1-T5_INSTALL		L	

Fan Switch / Interlock Field provided BY OTHERS