


# **Gas-Fired Tempered Make-Up Air Unit**

## Model:

T2-3400-208-3

3-Phase, 208V, 2.00 HP, Belt driven with Motorized Damper and 12" Blower. MAX 3,400 CFM



Tel: (440) 365-4567

Fax: (440) 365-2100

www.naksinc.com







T2-HOX Direct Fired (481 lbs.)

#### **Supply Motor:**

Model EM3558T, 2.00 HP, 208-3-60, 6.60 FLA, TEFC (Totally Enclosed Fan Cooled)

#### **Supply Motor Pulleys:**

Part Type	<u>Qt</u> y	Browning #	Turns Out
Blower Pulley	1	AK54 x 3/4	
Motor Pulley	1	1VP40 x 7/8	2.0

#### Burner:

Min Output BTU: 18,000 BTU/Hr Max Output BTU: 375,000 BTU/Hr

Size: 6" long Gas Type: Natural

#### **Supply Performance:**

Volume: 3400 cfm Volume Range: 1400-3400 cfm

RPM: 1072 TS: 3613 ft/min SP: 1.69" w.g.

0.50" Ext. + 0.80" Int. + 0.39" Opt.

BHP: 1.74

#### **Heating Schedule:**

Altitude: 0'

Winter Entering Air Dry Bulb Temp: 0°F

Temp Rise: 100°F Output BTU: 345,000 Input BTU: 375,000

BTUs BASED OFF STANDARD AIR DENSITY

#### **Supply Installation Information:**

Gas Inlet Pressure: 8 in. w.c. - 14 in. w.c.

Insurance: FM/ETL

Unit Main Input: 11.25 Amps MCA, 15 Amps MOP, 208V,

14 AWG Wire Min.

Supply Unit Voltage: 208v-3ph-60hz

#### Construction Features

Housing constructed of heavy-duty unpainted G90 galvanized steel • Forward curved centrifugal blower wheel • Vibration isolation • Adjustable drive assemblies • Adjustable motor mount • Ball bearing motors • Heavy duty, pre-lubricated bearings L10 rated for 100,000 hours of operation • Static resistant belts • Service doors on both sides • Horizontal & down discharge • Large intake area ensures low pressure drop across unit • Electronic Burner Profiler System automatically adjusts for any airflow - no manual setting required! • Weatherproof safety disconnect switch • Modular design provides design flexibility • Fully insulated casing

#### Blower:

12" forward curved, centrifugal blower. Permanently lubricated ball bearings. Galvanized finish. 3/4" shaft. 2,500 max. RPM. Used in heated and non-heated supply fans.

#### **Temp Control:**

Maxitrol Series 14 • 40-90°F Discharge Temp Control • Field Wired On/Off Start Command; Temperature set point dial @ main/unit panel.

#### Intake:


Sloped Filtered Intake for T2 Modular Heater. 28" Wide x 32" Long x 30" High. Includes 2" MV EZ Kleen Metal Mesh Filters.


#### Filters:

2x MV EZ Kleen Metal Mesh Filter.  $20"x\ 25"x\ 2"$  Used for heater and supply fan intakes.

#### **Selected Options:**

- Motorized Inlet Damper 20"W x 23-3/4"H for T2 Modular Heating Units w/Extended Shaft, Standard Galvanized Construction, 3/4" Rear Flange, LMX24-3-S Belimo Actuator Included (with end switch)
- Low Fire Start. Allows the burner circuit to energize when the modulation control is in a low fire position.





481 LBS.

TOTAL APPROXIMATE WEIGHT:

SA

3 5/16 🗖


			12-3
1	T2-H0X	08-2020	
	MODEL:	DATE:	DRAWING NO.
	ı	BMA	
PROJECT NAME:	REF. NO./JOB NO.:	DRAWN BY:	CERTIFIED BY:
DESCRIPTION OF REVISION	1	I	-
BY	-	ı	1
DATE	-	ı	
REV	-	ı	1

NONE

-3400 - 208 - 3SCALE TAG



l						
	REV.	DATE	BY	DESCRIPTION OF REVISION	PROJECT NAME:	
	-1	ı	1	ı	REF. NO./JOB NO.: -	MODEL
	1	-	1	ı	DRAWN BY: BMA	DATE
	1	1	1	1	CERTIFIED BY:	DRAWIN



Contractor:

Model Informa	tion											
Model	: G12				Part Nu	ımber:	900546	64				
CFM	3400			Sh	aft Dia	meter:	0.75		Unit	Weight:	48	
SP	: 1.69			Wh	eel Dia	meter:	12.875		Ship	Weight:	52	
RPM	: 1072				Tip S	Speed:	3613 F	PM				
BHP	: 1.74			Sta	tic Effic	iency:	52		Е	levation:	0	
				0	utlet Ve	elocity:	2332 F	PM	Temp	perature:	70	
Sound Data	63	125	250	500	1000	2000	4000	8000	(Hz)	LwA:	85	

Sound Power Level @ Frequency, re: 10^12 Watts 89 91 86 82 77 77 74 71 (dB) SONES: 24.8


Ducted inlet or ducted outlet dBA @5 ft. 74


Ducted inlet and ducted outlet dBA @5 ft. 54

### **Performance Curve**

**Equipment Tag** 

### DELHI Model G12 CFM=3400 SP=1.69 BHP=1.74 S. Eff=52% RPM=1072










## 115-1-60


## 208/230-1-60

## 208/230/460/575-3-60











PROJECT NAME:	NAKS T1-T5 DIRECT	FIRED M	IUA INSTALLAT	TON WIRING	
REF. NO./JOB NO.:	_	MODEL:	T1-T5	TAG:	_
DRAWN BY:	_	DATE:	06-2020	SCALE:	NONE
CERTIFIED BY:		DRAWING	NO.:	T1-T5_INSTAL	L

Fan Switch / Interlock Field provided BY OTHERS