



It is the responsibility of the architect/owner to ensure that the hood clearance from limited-combustible and combustible materials is in compliance with local code requirements

Condensate (Type II)
Hood General Specifications

- Hoods are built in accordance with NFPA 96, NSF Specifications and Conforms to UL 710 Standards
- Hoods are constructed of 18 gauge 304 Stainless Steel
- All joints are welded liquid tight, without seams
- Wire Mesh and Framed Filter (Shipped Loose)
- Full Perimeter Gutter w/ Drain
- Factory does not cut holes in hood
 - Hoods 10' and larger receive 6 hanger brackets total
- All Stainless Steel

