



## VERIFY

the vehicle is jacked or wheel chocks are installed around wheels [NFPA 96:B.13.3] and that there is at least 10 ft clearance from buildings or structures, combustible materials, vehicles, and other cooking operations. [NFPA 1:50.7.1.5]

## VERIFY ACCESS & ENSURE CLEARANCE

Verify fire department vehicular access is provided for fire lanes, access roads, fire hydrants, and fire department connections. [NFPA 1:50.7.17]

